

---

**Test Procedure for**

**SLUMP OF HYDRAULIC CEMENT CONCRETE**



**TxDOT Designation: Tex-415-A**

**Effective Date: July 2008**

---

**1. SCOPE**

- 1.1 This test method describes the procedure for determining slump of freshly mixed plastic hydraulic cement concrete in the laboratory and in the field.
  - 1.2 The values given in parentheses (if provided) are not standard and may not be exact mathematical conversions. Use each system of units separately. Combining values from the two systems may result in nonconformance with the standard.
- 

**2. PROCEDURE**

- 2.1 Refer to ASTM C 143 for the test procedure, as supplemented by the following.
  - 2.1.1 Remove aggregate larger than 1-1/2 in. by hand or by wet sieve method.
- 

**3. ARCHIVED VERSIONS**

- 3.1 Archived versions are available.